

POLYSOL – Thermal and electrical performance assessment of a cost-effective polygeneration system



1st Nordic Conference on
Zero Emission and Plus Energy Buildings

Towards low carbon built environments

J. Soares, B. Shahzamanian, S. Varga, A. Palmero-Marrero, A. C. Oliveira

CONTENTS

- **Objectives;**
- **Existing Test and Demonstration Facility;**
- **Methodology – numerical model;**
- **Results:**
 - Yearly thermal performance;
 - Yearly electrical performance;
- **Conclusions;**
- **Acknowledgements;**




Since 1986

Objectives


POLYSOL – Development of a polygeneration solar system for Zero Energy Building

The objective of POLYSOL is to develop and evaluate, both numerically and experimentally, a polygeneration system satisfying the electricity, cooling and heating needs of buildings.




Specific objective: Identification of thermal and electric energy consumption of the test facility throughout the year

Existing Test and Demonstration Facility (TDF)




General layout of the TDF



Installed electric capacity (measured)


Research methodology

Numerical model for thermal load assessment on the building




Research methodology

Numerical model validation




Results

Yearly thermal performance





Results

Yearly thermal performance




Results

Yearly electrical performance




Results

Yearly electrical performance




Results

Electrical performance in a selected summer day – example



Conclusions



Thermal Energy

$Q_{\text{solar,annual}} \approx 16 \text{ MWh}_{\text{th}}$ (about 6 times the demand);

$Q_{\text{demand,cooling}} \approx 64 \%$

Shortages on the hourly and daily levels:

- highest cumulative thermal energy deficit ($19 \text{ kWh}_{\text{th}}$) for the 14th and 15th of February;
- TES will be used. About $37 \text{ kWh}_{\text{th}}$ excess on the 13th of February;



Electrical Energy

$W_{\text{elect,demand}} \approx 1.9 \text{ MWh}_{\text{el}}$;

$W_{\text{elect,PV}} \approx$ about 1.6/1.7 times the demand (7 and 8 PV modules, respectively);

Shortages on the hourly and daily levels:

- highest cumulative electrical energy deficit ($11 \text{ kWh}_{\text{th}}$) for the 1st and 3rd of January;
- peak shortage $\approx 0.8 \text{ kW}_{\text{el}}$ occurs in summer ;

Szabolcs Varga

szabolcs@fe.up.pt

INSTITUTE OF SCIENCE AND INNOVATION IN MECHANICAL
AND INDUSTRIAL ENGINEERING

www.inegi.up.pt



The authors gratefully acknowledge the financial support of “**Fundação para a Ciência e Tecnologia**” (FCT – Portugal), through the research project POCI-01-0145-FEDER-030223 (“Development of a polygeneration solar system for Zero Energy Building”).